

Optimal Sensor Placement for Identification of Electrical Networks using Noisy Measurement Data

Aranya Chakraborty

Electrical & Computer Engineering Department
North Carolina State University

Clyde F. Martin

Department of Mathematics,
Texas Tech University


KTH Power Workshop, 25th May, 2011




Network Model Identification

Assuming that voltage, phase and frequency measurements from the terminal buses of every tie-line of the power network are available (directly or by observability):

How to choose the best set of (virtual) measurement locations on the tie-lines to generate accurate second-order models, especially when the PMU data are noisy and unreliable



Network Model Identification



$$p_{ik} = r_{ik}^2 + x_{ik}^2, \quad \alpha_{ik} = \tan^{-1}(x_{ik}/r_{ik})$$

$$\dot{\delta}_i = \omega_i$$

$$2H_i \dot{\omega}_i = P_{mi} - \sum_{k \in N_i} \left(\frac{E_i^2 r_{ik} - E_i E_k p_{ik} \cos(\delta_{ik} + \alpha_{ik})}{p_{ik}^2} \right)$$

2nd order oscillators connected over a planar network graph

Nodes represent electrical generators, Edges denote the intertie lines

Edges have impedances with a real resistive part and an imaginary reactive part

Dynamics of each generator are driven by power balance with its neighbors following Newton's law

Assume direct connection between the oscillators implying that the graph is a connected differential network (and not a differential-algebraic network)

Identification of Network Model Parameters


$$\dot{\delta}_i = \omega_i$$

$$2H_i \dot{\omega}_i = P_{mi} - \sum_{k \in N_i} \left(\frac{E_i^2 r_{ik} - E_i E_k p_{ik} \cos(\delta_{ik} + \alpha_{ik})}{p_{ik}^2} \right)$$

$$\delta_{ik} = \delta_i - \delta_k, \quad p_{ik} = r_{ik}^2 + x_{ik}^2, \quad \alpha_{ik} = \tan^{-1}(x_{ik}/r_{ik})$$

Problem:

How to estimate the parameters: E_p E_q H_p H_q r_{pq} x_{pq}



$$E_p = \text{Re}(\tilde{V} - \bar{z}_{pq} \tilde{I})$$

$$E_q = \text{Re}(\tilde{V} + (\tilde{z}_{pq} - \bar{z}_{pq}) \tilde{I})$$

Estimate: H_p H_q r_{pq} x_{pq}

Identification of Network Model Parameters

Small-signal Model

$$\begin{bmatrix} \Delta \dot{\delta} \\ \Delta \dot{\omega} \end{bmatrix} = \begin{bmatrix} 0 & I \\ \mathcal{L} & 0 \end{bmatrix} \begin{bmatrix} \Delta \delta \\ \Delta \omega \end{bmatrix} + \begin{bmatrix} 0 \\ \mathcal{E} \end{bmatrix} u$$

Laplacian Structure

$$\mathcal{L}_{pp} = - \sum_{q \in N_p}^n \frac{E_p E_q}{2H_p z_{pq}} \sin(\delta_{pq0} + \alpha_{pq0})$$
$$\mathcal{L}_{pq} = \frac{E_p E_q}{2H_p z_{pq}} \sin(\delta_{pq0} + \alpha_{pq0}), \quad q \in N_p$$
$$\mathcal{L}_{pq} = 0, \quad \text{otherwise}$$

- Straightforward in the deterministic case
- Standard Least-squares methods (ARMA) can be applied
- Linearize the swing model, apply an impulse input, observe the output, estimate parameters from i/o identification

Identification of Network Model Parameters

Small-signal Model

$$\begin{bmatrix} \Delta \dot{\delta} \\ \Delta \dot{\omega} \end{bmatrix} = \begin{bmatrix} 0 & I \\ \mathcal{L} & 0 \end{bmatrix} \begin{bmatrix} \Delta \delta \\ \Delta \omega \end{bmatrix} + \begin{bmatrix} 0 \\ \mathcal{E} \end{bmatrix} u$$

Laplacian Structure

$$\mathcal{L}_{pp} = - \sum_{q \in N_p}^n \frac{E_p E_q}{2H_p Z_{pq}} \sin(\delta_{pq0} + \alpha_{pq0})$$
$$\mathcal{L}_{pq} = \frac{E_p E_q}{2H_p Z_{pq}} \sin(\delta_{pq0} + \alpha_{pq0}), \quad q \in N_p$$
$$\mathcal{L}_{pq} = 0, \quad \text{otherwise}$$

- Straightforward in the deterministic case
- Standard Least-squares methods (ARMA) can be applied
- Linearize the swing model, apply an impulse input, observe the output, estimate parameters from i/o identification

- However, if PMU measurements are noisy - parameter estimates are probabilistic
- Estimation must be posed in terms of estimation error bounds – **Cramer Rao** bounds

Statistical Preliminaries

- Given a data sequence $y(t)$, we consider the estimator $g(y)$ to estimate the parameter vector θ

- Let the Fisher Information Matrix (FIM) for the θ be $J(\theta)$

- Estimation error covariance:


$$C_g = E[(g(y) - \theta)(g(y) - \theta)^T]$$

- Cramer Rao bound: $C_g \leq J^{-1}(\theta)$

- For LTI systems (McWhorter & Scharf):

$$y = x(\theta) + n \quad n : N[0, R]$$

$$J(\theta) = \left(\frac{\partial x}{\partial \theta} \right) R^{-1} \left(\frac{\partial x}{\partial \theta} \right)^T$$



$$\theta = \text{col}(a, b)$$

$$J(a, b) = \frac{1}{\sigma^2} \begin{bmatrix} HH^T & HK^T \\ KH^T & KK^T \end{bmatrix}$$

where:


$$R = \sigma^2 I \quad H = \frac{\partial x}{\partial a} \quad K = \frac{\partial x}{\partial b}$$

Statistical Preliminaries

- Given a data sequence $y(t)$, we consider the estimator $g(y)$ to estimate the parameter vector θ
- Let the Fisher Information Matrix (FIM) for the θ be $J(\theta)$
- For LTI systems (McWhorter & Scharf):




$$y = x(\theta) + n \quad n : N[0, R]$$

$$J(\theta) = \left(\frac{\partial x}{\partial \theta} \right) R^{-1} \left(\frac{\partial x}{\partial \theta} \right)^T$$




$$\theta = \text{col}(a, b)$$

$$J(a, b) = \frac{1}{\sigma^2} \begin{bmatrix} HH^T & HK^T \\ KH^T & KK^T \end{bmatrix} \text{ where: } H = \frac{\partial x}{\partial a} \quad K = \frac{\partial x}{\partial b}$$

-  For our model the FIM $J(a, b)$ is a function of the spatial location of the PMU
-  There exists an 'optimal location' that generates the tightest CRB
-  If there is no internal output feedback on any point of the edge from the terminal buses, then computation is decentralized (CDC 2010)
 - for example, if there is a SVC for voltage regulation then a centralized algorithm is needed

Two-node System




$$\dot{\delta} = \omega$$

$$2 \frac{H_1 H_2}{H_1 + H_2} \dot{\omega} = \frac{H_2 P_{m1} - H_1 P_{m2}}{H_1 + H_2} - \frac{E_1 E_2}{(x_1 + x_e + x_2)} \sin \delta$$

• Linearize: $\dot{m} = \begin{bmatrix} 0 & 1 \\ -\frac{E_1 E_2}{2H\bar{x}} \cos(\delta_o) & 0 \end{bmatrix} m + \begin{bmatrix} 0 \\ 1 \end{bmatrix} u$ $m = [\Delta\delta, \Delta\omega], \quad 0 < \delta_o < 90^\circ$

Two-node System



$$\dot{\delta} = \omega$$

$$2 \frac{H_1 H_2}{H_1 + H_2} \dot{\omega} = \frac{H_2 P_{m1} - H_1 P_{m2}}{H_1 + H_2} - \frac{E_1 E_2}{(x_1 + x_e + x_2)} \sin \delta$$

• Linearize:
$$\dot{m} = \begin{bmatrix} 0 & 1 \\ -\frac{E_1 E_2}{2H\bar{x}} \cos(\delta_o) & 0 \end{bmatrix} m + \begin{bmatrix} 0 \\ 1 \end{bmatrix} u$$


$$m = [\Delta\delta, \Delta\omega], \quad 0 < \delta_o < 90^\circ$$

- Assume output as voltage magnitude V measured at distance x from Gen 2

$$a = x / \bar{x}$$

$$\bar{x} = x_1 + x_e + x_2$$

Two-node System



$$\dot{\delta} = \omega$$

$$2 \frac{H_1 H_2}{H_1 + H_2} \dot{\omega} = \frac{H_2 P_{m1} - H_1 P_{m2}}{H_1 + H_2} - \frac{E_1 E_2}{(x_1 + x_e + x_2)} \sin \delta$$

• Linearize: $\dot{m} = \begin{bmatrix} 0 & 1 \\ -\frac{E_1 E_2}{2H\bar{x}} \cos(\delta_0) & 0 \end{bmatrix} m + \begin{bmatrix} 0 \\ 1 \end{bmatrix} u$ $m = [\Delta\delta, \Delta\omega], \quad 0 < \delta_0 < 90^\circ$

- Assume output as voltage magnitude V measured at distance x from Gen 2


$$a = x / \bar{x}$$

$$\bar{x} = x_1 + x_e + x_2$$

• From Ohm's law: $V = \sqrt{E_2^2 (1-a)^2 + E_1^2 a^2 + 2E_1 E_2 a(1-a) \cos(\delta)}$

• Output matrix: $C = \left[\frac{\partial V}{\partial \delta} \quad \frac{\partial V}{\partial \omega} \right]_{\delta_0, 0} = \left[\frac{-a(1-a)E_1 E_2 \sin(\delta_0)}{V_0(a)} \quad 0 \right] \rightarrow \text{Function of } a$


Two-node System



Discrete-time Transfer Function

$$G(z) = \psi(a) \frac{K(z+1)}{z^2 - 2\cos(\gamma T)z + 1},$$

$$\psi(a) = a(1-a)/V_0(a)$$




Voltage Magnitude as Output

$$V(k, a) = \psi(a) \xi(k, x_1, x_2, H_1, H_2) \quad k = 1, 2, 3, \dots$$

unknown parameters

$$\alpha = \{x_1, x_2\} \quad \beta = \{H_1, H_2\}$$


Two-node System



Discrete-time Transfer Function

$$G(z) = \psi(a) \frac{K(z+1)}{z^2 - 2\cos(\gamma T)z + 1},$$

$$\psi(a) = a(1-a)/V_0(a)$$



Voltage Magnitude as Output

$$V(k, a) = \psi(a) \xi(k, x_1, x_2, H_1, H_2) \quad k = 1, 2, 3, \dots$$


unknown parameters
 $\alpha = \{x_1, x_2\} \quad \beta = \{H_1, H_2\}$

Construction of FIM

• Stack:

$$Y(a, k) = \text{col}[V(1), V(2), \dots, V(k)] \quad \alpha = \{x_1, x_2\} \quad \beta = \{H_1, H_2\}$$

$$H(a) = \frac{\partial Y}{\partial \alpha} \quad K(a) = \frac{\partial Y}{\partial \beta}$$




$$J(a, \alpha, \beta) = \frac{1}{\sigma^2} \begin{bmatrix} HH^T & HK^T \\ KH^T & KK^T \end{bmatrix}$$



Function of a

Two-node System



- **Recall:** Minimizing the estimation error bound = $\min J^{-1}$
- Equivalently, for any given set of measurements, **maximize** $\det(J)$
- **Main Result:** Find a such that the determinant of $J(a)$ is maximised

$$J(a, \alpha, \beta) = \begin{bmatrix} HH^T & HK^T \\ KH^T & KK^T \end{bmatrix}$$

$$a \in [a_1, a_2]$$

$$a_1 = \frac{x_2}{x_1 + x_e + x_2} \quad a_2 = \frac{x_2 + x_e}{x_1 + x_e + x_2}$$

$$\max \psi^2 \det(\psi_x^2 L_1 + \psi_x \psi L_2 + \psi^2 L_3)$$

$$st. x \in [x_2, x_e + x_2]$$

PMU's can only be placed on the transmission line, not inside the areas

Estimation Algorithm

Algorithm 1 Calculate \mathcal{A}^* for model (4)-(5)

Choose $\mathcal{A}(i) \in [0, 1]$, $i = 1, 2, \dots, m$

$f = 1$, $0 < \epsilon^* \ll 1$

if $f = 1$ then

Measure: $\tilde{y}_j(a_j, k)$, $k = 1, 2, \dots, l$, $j = 1, 2, \dots, m$

Solve:

$$\hat{\Theta}_{ML} = \max_{\Theta} \sum_{j=1}^m \sum_{k=1}^l \left\{ \tilde{y}_j(\mathcal{A}(j), k) * y_j(\mathcal{A}(j), k, \Theta) \right\}$$

$$\mathcal{A}^* = \max_{\mathcal{A}} \det(J(\hat{\Theta}_{ML}, \mathcal{A})), \quad \mathcal{A}(i) \in [0, 1]$$

Set $\epsilon = \|\mathcal{A} - \mathcal{A}^*\|_2$

Set $\mathcal{A} = \mathcal{A}^*$

if $\epsilon \leq \epsilon^*$ then

$f = 0$

else

$f = 1$

end if


end if

\Rightarrow Local convexity in a


\Rightarrow

\Rightarrow Global convexity needs uniformity
in all parameters in \mathcal{S}


Simulations




Bus 1 voltage



Bus 2 voltage





Parameter s	Actual Values	Iteration 1	Iteration 1	Iteration 1	Iteration 1	Iteration 1
r	0.1	0.05	0.06	0.08	0.08	0.093
x	1	0.58	0.64	0.78	0.83	0.981
H_1	19	15.65	17.91	17.65	18.55	18.98
H_2	13	10.86	10.91	11.68	12.35	12.75
a	-	0.428	0.412	0.409	0.408	0.408





Spatial variation of the determinant of the FIM

Application to WECC Data




More than Two Areas: Pacific AC Intertie



Salient Points

- Current in each branch is different
- No *single* spatial variable a
- Derivations need to be done *piecewise* (each edge of the star)
- Two interarea modes/ relative states – δ_1 & δ_2

• Chakraborty & Salazar (2009, 2010)




$$V_n = J_1(x)\Delta\delta_1(t) + J_2(x)\Delta\delta_2(t)$$

$$\frac{V_n^3}{V_n^4} = \frac{J_1^3(x)\Delta\delta_1(t^*) + J_2^3(x)\Delta\delta_2(t^*)}{J_1^4(x)\Delta\delta_1(t^*) + J_2^4(x)\Delta\delta_2(t^*)}$$

Time-space separation property lost!

Pacific AC Intertie



Solution – Use phase angle as a 2nd degree of freedom

$$\theta = \tan^{-1} \left(\frac{f_1(x) \sin(\delta_1) + f_2(x) \sin(\delta_2)}{f_1(x) \cos(\delta_1) + f_2(x) \cos(\delta_1) + f_3(x)} \right)$$

$$\Delta \theta(t) = S_1(x) \Delta \delta_1(t) + S_2(x) \Delta \delta_2(t)$$


Measurable if a PMU
is installed at that point

Voltage equation


$$\frac{V_n^3}{V_n^4} = \frac{J_1^3(x) \Delta \delta_1(t^*) + J_2^3(x) \Delta \delta_2(t^*)}{J_1^4(x) \Delta \delta_1(t^*) + J_2^4(x) \Delta \delta_2(t^*)}$$

Phase equation

$$\frac{\Delta \theta^3}{\Delta \theta^4} = \frac{S_1^3(x) \Delta \delta_1(t^*) + S_2^3(x) \Delta \delta_2(t^*)}{S_1^4(x) \Delta \delta_1(t^*) + S_2^4(x) \Delta \delta_2(t^*)}$$



Adding Phase & Frequency Information in the Output



Use a linear combination of outputs

$$y(k) = \mu_1 \left(\psi(a_{pq}) \xi(k) \right) + \mu_2 \rho(a_{pq}, k) + \mu_3 \mathcal{G}(a_{pq}, k)$$

$$\mu_1 + \mu_2 + \mu_3 = 1$$

- For any branch e_{pq}

Phase

$$\theta_{pq} = \tan^{-1} \frac{a_{pq} E_p \sin(\delta_p) + (1 - a_{pq}) E_q \sin(\delta_q)}{a_{pq} E_p \cos(\delta_p) + (1 - a_{pq}) E_q \cos(\delta_q)}$$

$$\Delta \theta_{pq}(k) = \underset{\rho(a_{pq}, k)}{\underset{1 \ 4 \ 4 \ 4 \ 2 \ 4 \ 4 \ 3}{z^{-1} \left(C_{pq}^{\theta} (zI - A_d)^{-1} B_d \right)}}$$

Frequency

$$f_{pq} = \dot{\theta}_{pq} = \frac{\partial \theta_{pq}}{\partial \delta_p} \omega_p + \frac{\partial \theta_{pq}}{\partial \delta_q} \omega_q = C_1 \omega_p + C_2 \omega_q$$

$$\Delta f_{pq}(k) = \underset{\mathcal{G}(a_{pq}, k)}{\underset{1 \ 4 \ 4 \ 4 \ 2 \ 4 \ 4 \ 3}{z^{-1} \left(C_{pq}^f (zI - A_d)^{-1} B_d \right)}}$$

Adding Phase & Frequency

For any edge e_{pq} :

1. Voltage Magnitude (volts)

2. Voltage Phase Angle (rad)

3. Bus Frequency (rad/sec)

$$V(k, a) = \psi_1(a) \xi_1(k, r, x, H_1, H_2) \quad \theta(k, a) = \psi_2(a) \xi_2(k, x, r, H_1, H_2) \quad f(k, a) = \psi_3(a) \xi_3(k, R, x, H_1, H_2)$$

$$k = 1, 2, 3, \dots$$

Combined output:

$$y(k, a) = \mu_1 V(k, a) + \mu_2 \theta(k, a) + \mu_3 f(k, a)$$

$$\mathbf{H}_{pq} = \frac{\partial y_{pq}}{\partial \mathbf{s}_1} = \mu_1 \left(\frac{\partial \psi(a_{pq})}{\partial \mathbf{s}_1} \xi(k) + \psi(a_{pq}) \frac{\partial \xi(k)}{\partial \mathbf{s}_1} \right) + \mu_2 \frac{\partial \rho(a_{pq}, k)}{\partial \mathbf{s}_1} + \mu_3 \frac{\partial \vartheta(a_{pq}, k)}{\partial \mathbf{s}_1}$$

$$\mathbf{K}_{pq} = \frac{\partial y_{pq}}{\partial \mathbf{s}_2} = \mu_1 \psi(a_{pq}) \frac{\partial \xi(k)}{\partial \mathbf{s}_2} + \mu_2 \frac{\partial \rho(a_{pq}, k)}{\partial \mathbf{s}_2} + \mu_3 \frac{\partial \vartheta(a_{pq}, k)}{\partial \mathbf{s}_2}$$

For exact expressions of the spatial functions please see

Chakraborty & Martin, CDC 2010, Atlanta

$$\max \det(J(a, \mu, \alpha, \beta)) = \det \begin{bmatrix} HH^T & HK^T \\ KH^T & KK^T \end{bmatrix}$$

$$a \in [a_1, a_2] \quad \mu_1 > 0, \mu_2 > 0, \mu_3 > 0$$


$$a_1 = \frac{x_2}{x_1 + x_e + x_2} \quad a_2 = \frac{x_2 + x_e}{x_1 + x_e + x_2}$$




Find optimal location of sensor,
and also optimal contribution
of measurement variables

Simulations


Voltage Magnitude (volts)




Phase Angle at Bus 1 (deg)



FIM for voltage magnitude



FIM for combined signals





Conclusions

1. A strategy for parameter estimation of swing models using noisy PMU data with a given Gaussian probability distribution
2. Estimation problem posed in terms of CR bounds
3. CRB is a function of the location of measurement
4. Not exactly a placement problem – more of an allocation problem
5. Even if a PMU is not placed exactly at the optimal point, the measurement at that point is still calculable from the terminal PMU's
6. Extensions: Transmission lines with intermediate voltage control, SVC feedback, TCSC (CDC 2010 - Part II, ACC 2011)

Acknowledgements: Marta Sczodrak, Bijoy Ghosh, NSF




Ongoing Phasor Research



Wide-area Monitoring

Situational Awareness (RTDMS, PGDA)
 Transient Stability
 Inter-area oscillations
 Power-angle curves



Wide-area Modeling

How to use PMU data
 for constructing area models

- So far deterministic
- Modeled for specific events
- Can be stochastic models (SAS may be interested)

1. Sponsor: NSF, 2010-2013 (PI: AC)
2. CISCO: Ch & Xin



Wide-area Control

How to design controllers for
 damping inter-area oscillations



- PSS
- FACTS

1. Sponsor: NSF, 2011-2016 (PI: AC)
2. CPS: Mueller, Chakraborty, Davis
 Dvsikiotis, Ch, Michailidis

Phasor Lab



Transient Network Analyzer



- Joint work with Subhashish Bhattacharya (NYPA, Siemens)
- Real-time emulation of the NY grid
- Actual controllers embedded in the system
- Create fault injections at vulnerable points, measure via 3 PMUs
- Ideal test-bed for small-scale dynamic visualization within NY state
- More ambitious – controller tuning for damping control

Thank You

[Email: aranya.chakraborty@ncsu.edu](mailto:aranya.chakraborty@ncsu.edu)

Homepage: people.engr.ncsu.edu/achakra2