

Smart-Grid Data Integrity Attacks: Characterizations and Countermeasures

Kameshwar Poolla
UC Berkeley

May 24, 2011

Co-conspirators

- Annarita Giani [Berkeley]
- Eilyan Bitar [Berkeley]
- Miles McQueen [Idaho National Labs]
- Pramod Khargonekar [Florida]

... and thanks to many useful discussions with:
Anjan Bose, Joe Eto, Pravin Varaiya

Outline

- 1 Introduction
- 2 Problem Set-up
- 3 Main Results
- 4 Future Directions

Cybersecurity of Electricity Grids

SCADA/EMS

Assumptions

- Simply connected power system
- n buses
 - injection buses [loads or generators]
 - null buses [zero external real power injected]
- Standard DC power flow assumptions [for now]
 - Quasi-steady state, balanced operation
 - Lossless lines
 - Reactive power support at all nodes
 - Small power angles

Power Meters

- Real power flow meters
 - Every injection bus
 - Some lines [need only one per line because lossless]
- The reality
 - All injection buses are metered [for settlement]
 - Only large > 50 MW are connected to SCADA network
 - Only large lines are metered [$\sim 10\%$]
 - Data transmitted to EMS at system operator every 2-10 seconds

Models

x bus voltage angles

y_1 injection meters

y_2 line meters

y $\begin{bmatrix} 0 & y_1 & y_2 \end{bmatrix}^T \in \mathbb{R}^{m+n}$

h $\mathbb{R}^n \rightarrow \mathbb{R}^{m+n}$

H bus susceptance matrix $\in \mathbb{R}^{(m+n) \times n}$

m number of line meters

n number of buses [including zero injections]

■ general nonlinear model $\mathcal{M} : y = h(x)$

■ DC power flow $\mathcal{L} : y = Hx$

Attacks

Definition

Attack $\mathcal{A} = (\mathbb{S}, a)$ consists of

\mathbb{S} set of compromised meters
 $a \neq 0$ attack vector $a = [0 \ a_1 \ a_2]^T \in \mathbb{R}^{m+n}$

Sparsity of $\mathcal{A} = |\mathbb{S}|$

- Meter readings y are changed to $y + a$
- Nonzero components of $a \leftrightarrow$ compromised meters \mathbb{S}

Unobservable Attacks

General model $y = h(x)$

Current operating point x^o

Current measurements $y^o = h(x^o)$

Definition

\mathcal{A} is *unobservable* at operating pt x^o wrt the model \mathcal{M} if

$$\exists x^a : y^o + a = h(x^o + x^a)$$

i.e. there exists some system state consistent with the compromised observations and model

x^a is the *perceived state* perturbation associated with \mathcal{A}

Unobservable Attacks ...

For linear DC power flow model \mathcal{L}

- \mathcal{A} is unobservable $\iff a = Hx^a$ is solvable
- unobservability is independent of current operating point

Theorem

*Consider DC power flow model $y = Hx$ and attack $\mathcal{A} = (\mathbb{S}, a)$.
 K delete rows corresp to \mathbb{S} from H*

(a) \mathcal{A} is unobservable if and only if $\text{rank}(K) < n$

(b) Attack vector a must lie in the subspace:

$$\mathcal{T} = \{a \in \mathbb{R}^{m+n} : a = Hx, Kx = 0\}$$

Coordination

- Unobservable attacks require **coordination**
- Attack vector must be arranged carefully across spatially separated meters
- Requires that attacker knows the model [and operating point]
- Consequence: low sparsity attacks are more probable
- Low sparsity unobservable attacks
 - Liu *et al* [2009]
 - 3-sparse attacks commonly exist in power system examples
- **Our research focus**
 - What do sparse attacks look like?
 - What countermeasures can we take?

Observable Islands

Definition

$\mathcal{A} = (\mathbb{S}, a)$: unobservable attack.

x^a : perceived state perturbation.

Partition the set of buses \mathbb{V} into disjoint union

$$\mathbb{V} = \mathbb{V}_1 \cup \dots \cup \mathbb{V}_s, \quad \mathbb{V}_i \cap \mathbb{V}_j = \emptyset \text{ for } i \neq j$$


defined by the equivalence classes

$$v_1, v_2 \in \mathbb{V}_i \iff x^a(v_1) = x^a(v_2)$$

The sets $\{\mathbb{V}_i, \dots, \mathbb{V}_s\}$ are the *observable islands* of attack \mathcal{A} .

Observable Islands Interpretation

- Unobservable attack \mathcal{A}
- Corresponds to some apparent power flow perturbation
- Apparent power flow must be on lines connecting islands
- No power flow between buses within same island



Related Work

- Liu et al (2009)
Showed existence of sparse unobservable attacks for common power system examples
- Bobba et al (2010)
Countermeasures using PMUs
- Kosut et al (2010)
Sufficient characterizations of unobservable attacks in terms of graph properties
- Teixeira et al (2010)
Measure of cyberattack resilience of a power system
Studies of vulnerability with nonlinear models
- Pasqualetti et al (2011)
Dynamic detection of attacks

Main Results

- 1 Irreducible Attacks
- 2 Attacks Involving 2 Power Injection Meters
- 3 Characterization of Sparse Attacks
- 4 Countermeasures using Known-secure PMUs
- 5 Countermeasures based on State-estimation
- 6 Beyond the DC Power Flow Model

A. Irreducible Attacks

Definition

$\mathcal{A} = (\mathbb{S}, a)$ is *irreducible* \iff there is no unobservable attack $\mathcal{A}' = (\mathbb{S}', a')$ with $\mathbb{S}' \subsetneq \mathbb{S}$

Theorem

Consider DC power flow model $y = Hx$ and attack $\mathcal{A} = (\mathbb{S}, a)$.

K delete rows corresp to \mathbb{S} from H

L keep row corresp to \mathbb{S} in H

- (a) If \mathcal{A} is irreducible then $\text{rank}(K) = n - 1$
- (b) Suppose $\text{rank}(K) = n - 1$. Let $0 \neq x \in \mathcal{N}(K)$. If all the entries of the vector Lx are nonzero, then \mathcal{A} is irreducible.
- (c) Attack vector a must lie in the one dimensional subspace:
$$\mathcal{T} = \{a \in \mathbb{R}^{m+n} : a = Hx, Kx = 0\}$$



B. Attacks Involving 2 Power Injection Meters

- Finding all irreducible attacks is NP hard
 - \equiv finding minimal sets of rows of H whose deletion reduces rank by 1
 - $O(mn!/k!(n-k)!)$ flops if there are k compromised injection meters
 - Computationally intractable problem even for small power networks
- Fast algorithm in special case of exactly 2 power injection meters
 - $O(n^2m)$ flops
 - 1 minute on a 3Ghz PC for CAISO 4000 bus system

Algorithm

```
0  | define  $G = \begin{bmatrix} H_0^T & H_1^T \end{bmatrix}^T$   
   |  $X = H_2 G^{-1}$   
1  | select any two injection nodes  $i$  and  $j$   
2  | define  $M^{i,j} = X[e_i e_j] \in \mathbb{R}^{m \times 2}$   
   | where  $e_i, e_j \in \mathbb{R}^n$  are unit vectors  
3  | use elementary column operations to factorize  
   |  $M^{i,j} \ T = \begin{bmatrix} 0_{r \times 1} & 0_{r \times 1} \\ 1 & 0 \\ 0 & 1 \\ x_1 & x_2 \end{bmatrix}$   
4  |  $I_1$  = indices of nonzero rows of  $x_1$   
   |  $I_2$  = indices of nonzero rows of  $x_2$   
5  |  $\mathcal{A}_1 = ([i, j, r + 2, r + I_1], a)$   
   |  $\mathcal{A}_2 = ([i, j, r + 1, r + I_2], a)$   
6  | goto 1
```


C. Characterization of Sparse Attacks

- Assume all lines are metered
- Can characterize 3,4,5 sparse attacks graphically

Theorem


$\mathcal{A} = (\mathcal{S}, a)$ is a 3-sparse irreducible attack \iff

- (a) \mathcal{S} consists of power meters at two adjacent injection buses and the power meter on the line ℓ connecting these buses
- (b) ℓ is a cutset of the power system graph



Characterization of Sparse Attacks ...

- Canonical forms for 4 sparse attacks
- Canonical forms for 5 sparse attacks
- Algorithm to find **all** k -sparse attacks, $k = 3, 4, 5$
 - find all instances of canonical forms in power system graph
 - depth-first search $O(n^2)$



D. Countermeasures using Known-secure PMUs

- PMUs are on the new NASPInet architecture
- Designed for security? Encrypted?
- Main idea
 - Disabling an attack with secure PMUs
 - Consider an unobservable attack \mathcal{A}
 - Associated observable islands $\mathbb{V}_1, \dots, \mathbb{V}_s$
 - If \mathcal{A} occurred, voltage phases between any pair of islands is $\neq 0$
 - Disable $\mathcal{A} \iff$ 2 PMUs are placed in any 2 distinct islands

Countermeasures using Known-secure PMUs ...

Theorem

Arbitrary collection of unobservable attacks $\mathbb{A} = \{\mathcal{A}_1, \dots, \mathcal{A}_p\}$

Observable islands:

$$\begin{array}{ccccccc}
 \text{attack } \mathcal{A}_1 & \mathbb{V}_1^1 & \mathbb{V}_2^1 & \dots & \mathbb{V}_{s_1}^1 & & \\
 \text{attack } \mathcal{A}_2 & \mathbb{V}_1^2 & \mathbb{V}_2^2 & \mathbb{V}_3^2 & \dots & \dots & \mathbb{V}_{s_2}^2 \\
 \vdots & \vdots & \vdots & \vdots & \vdots & & \\
 \text{attack } \mathcal{A}_p & \mathbb{V}_1^p & \dots & \mathbb{V}_{s_p}^p & & &
 \end{array}$$

\mathbb{A} is made observable by PMUs placed at buses \mathbb{B}

$$\iff \forall k, \exists i_1 \neq i_2 : \mathbb{V}_{i_1}^k \cap \mathbb{B} \neq \emptyset, \mathbb{V}_{i_2}^k \cap \mathbb{B} \neq \emptyset$$

i.e. every attack has two distinct islands which contain PMUs

Countermeasures using Known-secure PMUs ...

- minimal PMU placement \equiv vertex touching problem
- NP hard
- 2X approximations are P


Theorem

Consider any collection $\mathbb{A} = \{\mathcal{A}_1, \dots, \mathcal{A}_p\}$ of p unobservable attacks. It is sufficient to place $p + 1$ PMUs at specific buses to make every attack in the collection \mathbb{A} observable.

- algorithm complexity: $O(n^2p)$ flops
- sketch of proof [next slide]

Countermeasures using Known-secure PMUs ...

Sketch of proof:



E. Countermeasures using State Estimation

■ Method

- No additional sensors
- Modify BDD algorithm

■ Idea:

- Suppose we have an unobservable attack \mathcal{A} at time t^o
- State estimator will predict phase angle **translations** on observable islands
- Very unlikely if we have large islands

$$\gamma(\mathcal{A}) = \text{size of second largest island}$$

- γ is a measure of detectability of \mathcal{A}

- Attacks with large γ : sparse [few islands] – easily detected
- Attacks with small γ : involve many meters – improbable

F. Beyond the DC Power Flow Model

- Topological Observability: Korres *et al* [2003], Monticelli [2000]
- Attack $\mathcal{A}(\mathcal{S}, a)$ unobservable wrt linear model \mathcal{L}
 $\iff \mathcal{A}(\mathcal{S}, \hat{a})$ unobservable wrt nonlinear model \mathcal{N}
- attack vector \hat{a} for nonlinear model lives on a manifold
Sub-tangent space of $h(x)$ at current oper point
- Vulnerable sensor set \mathcal{S} is independent of
oper point, bus admittance values
depends only on topology

Future Directions

- Computational aspects of attack detection and classification
- Stale data problems
- Noise issues – graded observability notions
- Low-grade financially motivated cyberattacks
- Grid operations and cybersecurity