

---

# Some Control Theory Problems in Modern Energy Systems

Romeo Ortega


LSS-Supelec, France

## Contents:

- Dynamic Energy Router
- Transient Stability of Power Systems Revisited
- Wind Speed Estimator for Windmill Systems
- Other Control Problems


# Main Message: Paradigm Shift for Controller Design

Classical formulation: Signal-processing viewpoint



- System model and controller are signal processors:  $G_1 : e_1 \rightarrow y_1$ ,  $G_2 : e_2 \rightarrow y_2$ .
- Control specifications in terms of signals: tracking, disturbance attenuation, etc.
- Robustness represented via the “ $\Sigma - \Delta$  paradigm”, very successful for LTI systems: filtering reduces conservatism and easily computable.
- “Impossible” in nonlinear case:
  - nonlinear systems “mix” the frequencies,
  - far from obvious computations (NL filtering, Hamilton-Jacobi-Bellman PDE).

# Basis of Passivity-based Control



- View plant as **energy-transformation**, as opposed to signal-transformation, device
- Consider systems that satisfy (generalized) energy-conservation:

$$\text{Stored energy} = \text{Supplied energy} + \text{Dissipation}$$

- Control objective: preserve the energy-conservation property but with **desired** energy and dissipation functions

$$\text{Desired stored energy} = \text{New supplied energy} + \text{Desired dissipation}$$

In other words

$$\text{PBC} = \text{Energy Shaping} + \text{Damping Assignment}$$


- In many applications the natural viewpoint: active filters, FACTS, teleoperators, coordination/synchronization of large scale systems,...

---

# Dynamic Energy Router

# Formulation of the Energy Transfer Problem

Energy management between storing, generating and load units interconnected through power electronic devices



# Current Practice, Limitations and Objective

---


- Assume that system operates in steady state
- Translate power demand into current or voltage references
- Track references with PI controllers in the power converters
- Discriminate between fast and slow changing power demand via linear filtering
  - ⇒ Behavior below par during transients and for fast changing demands

Our objective is to propose a  $\Sigma_I$  that

- Does not rely on steady-state considerations
- Allows to incorporate dynamic restrictions of the units

# Mathematical Formulation of the Problem

- Units modeled as multiports  $\Sigma_j$  with port variables  $v_j(t), i_j(t) \in \mathbb{R}^m$



- They verify the energy conservation law

$$H_j(t) - H_j(0) = \int_0^t v_j^\top(s) i_j(s) ds - d_j(t),$$

- $H_j(t)$  is the stored energy,


- The supplied energy is,

$$\int_0^t v_j^\top(s) i_j(s) ds.$$

- $d_j(t) \geq 0$  is the dissipation.

# Duindam–Stramigioli Dynamic Energy Router

- DS–DER is a **power–preserving** interconnection  $\Sigma_I$  that transfer instantaneously the energy from one unit to the other. (Sanchez, *et al.*, IEEE–CSM'10)
- Assume, for simplicity, two ports



- $\Sigma_I$  is power preserving selecting

$$\Sigma_I : \begin{Bmatrix} i_1(t) \\ i_2(t) \end{Bmatrix} = \begin{bmatrix} 0 & \Gamma(t) \\ -\Gamma^\top(t) & 0 \end{bmatrix} \begin{Bmatrix} v_1(t) \\ v_2(t) \end{Bmatrix}$$

Indeed,

$$i_1^\top v_1 + i_2^\top v_2 = 0,$$

for any  $\Gamma \in \mathbb{R}^{n \times n}$ .



- Now, neglecting dissipation,

$$\begin{aligned}\dot{H}_1 &= v_1^\top i_1 = v_1^\top \Gamma v_2 \\ \dot{H}_2 &= v_2^\top i_2 = -v_2^\top \Gamma^\top v_1.\end{aligned}$$

- How to select  $\Gamma$ ? Take, for instance

$$\Gamma(t) = \alpha(t) v_1(t) v_2^\top(t), \quad \alpha(t) \in \mathbb{R}$$


then

$$\begin{aligned}\dot{H}_1 &= \alpha |v_1|^2 |v_2|^2 \\ \dot{H}_2 &= -\alpha |v_1|^2 |v_2|^2.\end{aligned}$$

- $\alpha > 0$  transfers all energy from  $\Sigma_2$  to  $\Sigma_1$ , ( $\alpha < 0$ , viceversa).
- Selecting the “shape” of  $\alpha(t)$  we can regulate the energy transfer rate.


# Experimental Results

- $\Sigma_1, \Sigma_2$  simple RC circuits.
- $\alpha(t)$  controls the direction and rate of change of energy flow.



- First,  $\alpha(t)$  is positive and constant. Then, it decreases at a slow rate, until it achieves its lower value.
- Remains constant for some time and then increase at a faster rate.
- Finally, it reaches its maximum value and remains there until the end.

# Power Electronics Implementation of DER



- Design a control law for the DER switches, which ensures that the currents track their desired references

$$\begin{bmatrix} i_1^*(t) \\ i_2^*(t) \end{bmatrix} = \begin{bmatrix} \alpha(t)v_1(t)v_2^2(t) \\ -\alpha(t)v_2(t)v_1^2(t) \end{bmatrix}.$$

- Fundamental problem: The energy of the DER verifies:



$$\dot{H}_I(t) = \underbrace{v_1(t)i_1(t) + v_2(t)i_2(t)}_{=0} - d_I(t) \leq 0,$$

and it becomes non-operational.



# Compensating the Dissipation

- Adding outer-loop PI's to a feedback linearizing control to regulate the voltage  $v_C(t)$ :


$$w_j(t) = -k_p \tilde{i}_j(t) - k_i \int_0^t \tilde{i}_j(s) ds - k_{pv} \tilde{v}_C(t) - k_{iv} \int_0^t \tilde{v}_C(s) ds, \quad j = 1, 2.$$



# Currents of $\Sigma_I$ and their References



# Voltage of DC Link



# Proposed Solution: Abandon Power Preservation

- Define mappings  $F_j(v)$  for the current references:

$$i_j^*(t) = F_j(v(t)), \quad j \in \bar{N},$$

- Two different objectives:

- Ensure the desired power dispatch,  $P_j^*(t) = v_j^\top(t) F_j(v(t))$ .
- Compensate dissipation,  $\sum_{j=1}^N v_j^\top(t) F_j(v(t)) = d_I(t)$ .

- Possible choice

$$F_j(v) = \delta_j \prod_{k=1, k \neq j}^N |v_k|^2 v_j, \quad \sum_{j=1}^N \delta_j(t) = d_I(t).$$

- If  $|v_j(t)| \geq \epsilon > 0$ , fix


$$F_j(v_j(t)) = \frac{P_j^*(t)}{|v_j(t)|^2} v_j(t),$$

with  $\sum_{j=1}^N P_j^*(t) = d_I(t)$ .

# Geometric Interpretation of the New DER and the DS-DER

Given  $v$  and  $d_I$ , the set  $F$  defines the admissible vectors  $F(v)$ , that satisfy


$$\sum_{j=1}^N v_j^\top(t) F_j(v(t)) = d_I(t).$$





# Simulation Results of the New DER


- A battery is added as a third port, to compensate the losses.




- Same energy pattern for the supercapacitors as before, i.e.  $P_1^*(t) = -P_2^*(t)$ , but

$$P_3^*(t) = d_I(t) = R_1 i_1^2(t) + R_2 i_2^2(t) + R_3 i_3^2(t).$$

# Power of Multiports



# Voltage of DC Link



---

# Transient Stability of Power Systems

# Model of the Power System

- We consider a large-scale power system consisting of  $n$  generators interconnected through a transmission network which we assume is lossy.
- The dynamics of the  $i$ -th machine with excitation is represented by the classical three-dimensional flux decay model

$$\dot{\delta}_i = \omega_i$$

$$\dot{\omega}_i = -D_i\omega_i + P_i - G_{ii}E_i^2 - E_i \sum_{j=1, j \neq i}^n E_j Y_{ij} \sin(\delta_i - \delta_j + \alpha_{ij})$$

$$\dot{E}_i = -a_i E_i + b_i \sum_{j=1, j \neq i}^n E_j \cos(\delta_i - \delta_j + \alpha_{ij}) + E_{fi} + u_i$$

- $\delta_i, \omega_{Mi}$ : rotor angle and speed,  $E'_{qi}$ : the quadrature axis internal voltage,  $u_{fi}$ : the **field excitation signal**,  $G_{Mij} = G_{Mji}$ ,  $B_{Mij} = B_{Mji}$  and  $G_{Mii}$ : conductance, susceptance and self-conductance of the generator  $i$ ,  $E_{fsi}$ : constant component of the field voltage,  $P_{mi}$ : constant mechanical power,  $x_{di}, x'_{di}, \omega_{i0}$  and  $D_{Mi}$ : direct-axis—synchronous and transient—reactances, synchronous speed and damping coefficient

# Problem Formulation and Solution

- Assume the model with  $u_i = 0$  has a stable equilibrium point at  $[\delta_{i*}, 0, E_{i*}]$ , with  $E_{i*} > 0$ . Find a control law  $u_i$  such that in closed-loop
  - an operating equilibrium is preserved,
  - a Lyapunov function for it is given and,
  - it is asymptotically stable with a well-defined domain of attraction.
- Two additional requirements are that the domain of attraction of the equilibrium is enlarged by the controller and that the Lyapunov function has an energy-like interpretation.
- For lossless lines we can assign

$$H_d(\delta, \omega, E) = \psi(\delta) + \frac{1}{2}|\omega|^2 + \frac{1}{2}(E - E_*)^\top \Gamma(E - E_*),$$


- If the lines are lossy we have to introduce a cross-term in the energy function.

$$H_d(\delta, \omega, E) = \psi(\delta) + \frac{1}{2}|\omega|^2 + \frac{1}{2}[E - \lambda(\delta)E_*]^\top \Gamma[E - \lambda(\delta)E_*].$$

- (Ortega, *et al.*, TAC'08)


# Simulations

- Consider the two machines system



- The disturbance is a three-phase fault in the transmission line that connects buses 3 and 5, cleared by isolating the faulted circuit simultaneously at both ends.
- This modifies the topology of the network and consequently induces a change in the equilibrium point.
- Without control the system is highly sensitive to the fault and the **critical clearing time** is almost zero.

# Load Angle and Internal Voltage, $t_{cl} = 80 \text{ m sec}$





# Other Results and Open Questions

---

- Considered also actuation via flexible AC transmission systems, (Manjarekar, *et al.*, Electrical Power Systems Research'10, EJC'11).
- Structure preserving models
  - Cyclo-dissipativity properties have been established and a linear controller proposed – leads to an LMI test, (Guisto, *et al.*, CDC'08).
  - “Full solution” using Lyapunov–based designs (Dib, *et al.*, TAC'10), (Casagrande, *et al.*, CDC'11).
- Alternative formulation as a synchronization, not stabilization, problem, (Dib, *et al.*, ACC'11).
  - Immersing a pendular dynamics.
  - Existence solution for  $n$  machines.

---

# Wind Speed Estimation in Windmill Systems

# Model of the Windmill System


- System is a wind turbine and a generator. The mechanical dynamics

$$(SM) \quad J\dot{\omega}_m = \frac{P_w}{\omega_m} - T_e.$$

- The mechanical power at the windmill shaft

$$P_w = \frac{1}{2} \rho A C_p(\lambda) v_w^3, \quad \lambda := \frac{r\omega_m}{v_w}.$$

- The power coefficient  $C_p(\lambda)$



# Wind Speed Estimation Problem

**Problem Formulation** Given the system, verifying:

- **Assumption 1** The power coefficient is a **known**, smooth, function  $C_p : [0, \lambda_M] \rightarrow \mathbb{R}_+$ , which verifies

$$C'_p(\lambda) \begin{cases} > 0 & \text{for } \lambda \in [0, \lambda^*) \\ = 0 & \text{for } \lambda = \lambda^* \\ < 0 & \text{for } \lambda \in (\lambda^*, \lambda_M], \end{cases}$$

where  $\lambda^* := \arg \max C_p(\lambda)$ .

- **Assumption 2** The wind speed  $v_w$  is an **unknown** positive constant.
- **Assumption 3** The electrical torque  $T_e$  and the motor speed  $w_m$  are **measurable**.
- **Assumption 4** For all  $\lambda \in (0, \lambda^*)$ , the power coefficient verifies

$$\frac{3}{\lambda} C_p(\lambda) > C'_p(\lambda).$$

Design an on-line estimate of the wind speed,  $\hat{v}_w$ , such that

$$\lim_{t \rightarrow \infty} \hat{v}_w(t) = v_w.$$

# Some Remarks

- $C_p(\lambda)$  can be easily obtained from experimental data, and the algorithm implemented from a [table look-up](#).
- Constant wind speed assumption only needed for the theory. An on-line estimator is able to [track slowly-varying parameters](#), assumption justified by the time scale separation between the wind dynamics and the mechanical and electrical signals.
- On-line estimators average the noise—in contrast with differentiator-based or extended Kalman filter schemes currently used.
- Measuring  $w_m$  and  $T_e$  is standard practice in windmill systems.
- Theory applicable also if blade pitch  $\beta$  is included, i.e.,  $C_p(\lambda, \beta)$ , or for more complete descriptions of the mechanical dynamics. For instance

$$\begin{aligned} I_r \dot{\omega}_r &= \frac{P_w}{\omega_m} - K_\theta \theta - B_\theta \dot{\theta} - B_r \omega_r \\ I_g \dot{\omega}_g &= -T_e + \frac{K_\theta}{N} \theta + \frac{B_\theta}{N} \dot{\theta} - B_g \omega_g \\ \dot{\theta} &= \omega_r - \frac{\omega_g}{N} \\ P_e &= T_e \omega_g. \end{aligned}$$

(FM)

# Main Estimation Result

**Proposition (Ortega, *et al.*, IJACSP'11)** Consider the system (SM), verifying Assumptions 1–4. The estimator

$$\begin{aligned}\dot{\hat{v}}_w^I &= \gamma \left[ T_e - \frac{\rho A}{2} \frac{(\hat{v}_w^I + \gamma \omega_m)^3}{\omega_m} C_p \left( \frac{r \omega_m}{\hat{v}_w^I + \gamma \omega_m} \right) \right] \\ \hat{v}_w &= \hat{v}_w^I + \gamma \omega_m,\end{aligned}$$

where  $\gamma > 0$ , is an adaptation gain, is asymptotically consistent, that is,

$$\lim_{t \rightarrow \infty} \hat{v}_w(t) = v_w.$$

**Remark** Assumption 4 is satisfied in the range where the torque coefficient has negative slope. Indeed,


$$C_T(\lambda) := \frac{1}{\lambda} C_p(\lambda),$$

satisfies


$$C'_T(\lambda) \leq 0 \Rightarrow \text{Assumption 4.}$$

# Simulation Results: Periodic Wind

Done in Vestas professional software, with the full model (FM) and real wind data.




# Simulation Results: Turbulent Wind





# Simulation Results: Gust



# Some Additional Results

---

## ● Energy quality

- Power factor compensation is equivalent to cyclo–dissipativation: The nonlinear non–sinusoidal case, (Garcia, *et al.*, IEEE-CSM'07).
- Passivity and robust PI control of the air supply system of a PEM fuel cell model, (Taj and Ortega, Automatica'11).

## ● Power converters

- An adaptive PBC for a unity power factor rectifier, (Escobar, *et al.*, IEEE TCST'01).
- Experimental comparison of several PWM controllers for a single-phase ac-dc converter, (Karagiannis, *et al.*, IEEE-TCST'03).
- An adaptive controller for the shunt active filter considering a dynamic load and the line impedance, (Valdez, *et al.*, IEEE-TCST'09).

## ● Drives

- Sensorless control of PMSM with guaranteed stability properties, (Shah, *et al.*, IFAC'11).
- PBC of doubly–fed induction machines, (Battle, *et al.*, EJC'07).